



LIFTING AND CARRIAGE PRECAUTIONS

- Check the weight on the CE label to select appropriate lift equipment .
- Before lifting the unit make sure that the external panel is firmly fixed in place.
- To use only lifting points provided.
- The chains or slings must be of equal length.
- To use a spread-bar to avoid damage to the unit.
- The movement must be performed with caution and avoid abrupt movements.
- Never move the unit on rollers.
- Never lift the unit using a fork-lift.



X: ELECTRIC FEED HOLE

LEGEND

HPG	High pressure gauge
LPG	Low pressure gauge
ATS	Spring type antivibrant mounting (Opt)
ATV	Rubber type antivibrant mounting (Opt)

MOD.	EMPTY WEIGHT	OPERATING WEIGHT	HYDRAULIC CONNECTIONS
EET.1210	9400 kg	9750 kg	DN200

Scala-Scale	Data-Date	30/03/15	Dis.to-Drawn	B.P.	N°Pezzi
Peso-Weight Kg.	Materiali-Materials				
Denominazione-Denomination					
WATER CHILLERS mod. EET.1210/CS.ST.NT.NP...					
Particolare-Detail					
Overall dimension - Lift Instruction					
FRAME 9750x2210x2450					

HITEMA®	
DIS.-DRAW N.	DIM-EET-1210ST01
Rev.	01-01/07/2015-M.S.
PROGRAM.N.	