



LIFTING AND CARRIAGE PRECAUTIONS

- Check the weight on the CE label to select appropriate lift equipment .
- Before lifting the unit make sure that the external panel is firmly fixed in place.
- To use only lifting points provided.
- The chains or slings must be of equal length.
- To use a spread-bar to avoid damage to the unit.
- The movement must be performed with caution and avoid abrupt movements.
- Never move the unit on rollers.
- Never lift the unit using a fork-lift.



LEGEND

HPG	High pressure gauge (Opt)
LPG	Low pressure gauge (Opt)
ATS	Spring type antivibrant mounting (Opt)
ATV	Rubber type antivibrant mounting (Opt)

MOD.	EMPTY WEIGHT	OPERATING WEIGHT	HYDRAULIC CONNECTIONS
SBS.095	1030 kg	1050 kg	DN50
SBS.120	1200 kg	1225 kg	DN65
SBS.145	1250 kg	1280 kg	DN65
SBS.160	1280 kg	1310 kg	DN65

Scala-Scale Data-Date 15/09/16 Dis.to-Drawn B.P. N°Pezzi

Peso-Weight Kg. Materiali-Materials

Denominazione-Denomination
WATER CHILLERS mod. SBS.095÷160/CS.B-ES.NT.NP.

Particolare-Detail
Overall dimension - Lift Instruction

REFRIGERANT R410a

HITEMA®

DIS.-DRAW N. DIM-SBS-095ST01

Rev. 01 - B.P. - 08/08/18

PROGRAM.N.