

- · Check the weight on the CE label to select appropriate lift equipment .
- Before lifting the unit make sure that the external panel is firmly fixed in place.
- To use only lifting points provided.
- The chains or slings must be of equal length.
- To use a spread-bar to avoid damage to the unit.
- The movement must be performed with caution and avoid abrupt movements.
- Never move the unit on rollers.
- Never lift the unit using a fork-lift.

HPG	High pressure gauge (Opt)		
LPG	Low pressure gauge (Opt)] _	
ATS	Spring type antivibrant mounting (Opt)		
ATV	Rubber type antivibrant mounting (Opt)		

MOD.	EMPTY WEIGHT	-	HYDRAULIC CONNECTIONS
SBS.1230	7600 kg	8100 kg	DN200

N₽ezzi Dis.to-Drawn Scala-Scale 15/09/16 Peso-Weight Kg. Materiali-Materials Denominazione-Denomination DIS.-DRAW N. DIM-SBS-1230ST01 WATER CHILLERS mod. SBS.1230/CS.ST.NT.NP. 01 - B.P. - 08/08/18 Rev. Overall dimension - Lift Instruction PROGRAM.N. REFRIGERANT R410a

