


LIFTING AND CARRIAGE PRECAUTIONS

- Check the weight on the CE label to select appropriate lift equipment .
- Before lifting the unit make sure that the external panel is firmly fixed in place.
- To use only lifting points provided.
- The chains or slings must be of equal length.
- To use a spread-bar to avoid damage to the unit.
- The movement must be performed with caution and avoid abrupt movements.
- Never move the unit on rollers.
- Never lift the unit using a fork-lift.



LEGEND

| | |
|-----|--|
| HPG | High pressure gauge (Opt) |
| LPG | Low pressure gauge (Opt) |
| ATS | Spring type antivibrant mounting (Opt) |
| ATV | Rubber type antivibrant mounting (Opt) |

| MOD. | EMPTY WEIGHT | OPERATING WEIGHT | HYDRAULIC CONNECTIONS |
|------------|--------------|------------------|-----------------------|
| SBS.470/F8 | 3900 kg | 4000 kg | DN150 |
| SBS.530 | 3950 kg | 4070 kg | DN150 |
| SBS.570 | 4050 kg | 4180 kg | DN150 |
| SBS.610 | 4100 kg | 4250 kg | DN150 |
| SBS.660 | 4170 kg | 4330 kg | DN150 |

| | | | |
|--|---------------------|--------------|---------|
| Scala-Scala | Data-Date | Dis.to-Drawn | N°Pezzi |
| | 15/09/16 | B.P. | |
| Peso-Weight Kg. | Materiali-Materials | | |
| Denominazione-Denomination | | | |
| WATER CHILLERS mod. SBS.530÷660/CS.ST.NT.NP. | | | |
| Particolare-Detail | | | |
| Overall dimension - Lift Instruction | | | |
| REFRIGERANT R410a | | | |



| | |
|--------------|----------------------|
| DIS.-DRAW N. | DIM-SBS-530ST01 |
| Rev. | 01 - B.P. - 08/08/18 |
| PROGRAM.N. | |