



### LIFTING AND CARRIAGE PRECAUTIONS

- Check the weight on the CE label to select appropriate lift equipment .
- Before lifting the unit make sure that the external panel is firmly fixed in place.
- To use only lifting points provided.
- The chains or slings must be of equal length.
- To use a spread-bar to avoid damage to the unit.
- The movement must be performed with caution and avoid abrupt movements.
- Never move the unit on rollers.
- Never lift the unit using a fork-lift.



### LEGEND

HPG	High pressure gauge ( Opt )	MOD.	EMPTY WEIGHT	OPERATING WEIGHT	HYDRAULIC CONNECTIONS
LPG	Low pressure gauge ( Opt )				
ATS	Spring type antivibrant mounting ( Opt )	SBSF.290	2900 kg	3080 kg	DN125
ATV	Rubber type antivibrant mounting ( Opt )	SBSF.330	2950 kg	3140 kg	DN125

Scala-Scale	Data-Date	Dis.to-Drawn	N°Pezzi	<b>HITEMA</b> <sup>®</sup>
	23/09/16	B.P.		
Peso-Weight Kg.	Materiali-Materials			
Denominazione-Denomination				DIS.-DRAW N.
WATER CHILLERS mod. SBSF.290÷330/CS.ST.NT.NP.				DIM-SBSF-290ST01
Particolare-Detail				Rev.
Overall dimension - Lift Instruction				01 - B.P. - 08/08/18
REFRIGERANT R410a				PROGRAM.N.