


### LIFTING AND CARRIAGE PRECAUTIONS

- Check the weight on the CE label to select appropriate lift equipment .
- Before lifting the unit make sure that the external panel is firmly fixed in place.
- To use only lifting points provided.
- The chains or slings must be of equal length.
- To use a spread-bar to avoid damage to the unit.
- The movement must be performed with caution and avoid abrupt movements.
- Never move the unit on rollers.
- Never lift the unit using a fork-lift.



### LEGEND

HPG	High pressure gauge ( Opt )
LPG	Low pressure gauge ( Opt )
ATS	Spring type antivibrant mounting ( Opt )
ATV	Rubber type antivibrant mounting ( Opt )

MOD.	EMPTY WEIGHT	OPERATING WEIGHT	HYDRAULIC CONNECTIONS
SBSF.380	3730 kg	4000 kg	DN150
SBSF.430	4020 kg	4300 kg	DN150
SBSF.470	4100 kg	4400 kg	DN150

Scala-Scala	Data-Date	Dis.to-Drawn	N°Pezzi
	23/09/16	B.P.	
Peso-Weight Kg.	Materiali-Materials		
Denominazione-Denomination			
WATER CHILLERS mod. SBSF.380÷470/CS.ST.NT.NP.			
Particolare-Detail			
Overall dimension - Lift Instruction			
REFRIGERANT R410a			

**HITEMA®**

DIS.-DRAW N. DIM-SBSF-380ST01

Rev. 01 - B.P. - 08/08/18

PROGRAM.N.