



LIFTING AND CARRIAGE PRECAUTIONS

- Check the weight on the CE label to select appropriate lift equipment .
- Before lifting the unit make sure that the external panel is firmly fixed in place.
- To use only lifting points provided.
- The chains or slings must be of equal length.
- To use a spread-bar to avoid damage to the unit.
- The movement must be performed with caution and avoid abrupt movements.
- Never move the unit on rollers.
- Never lift the unit using a fork-lift.



LEGEND

HPG	High pressure gauge (Opt)	MOD.	EMPTY WEIGHT	OPERATING WEIGHT	HYDRAULIC CONNECTIONS
LPG	Low pressure gauge (Opt)	SBSF.840	7750 kg	8300 kg	DN200
ATS	Spring type antivibrant mounting (Opt)	SBSF.930	8000 kg	8600 kg	DN200
ATV	Rubber type antivibrant mounting (Opt)	SBSF.1030	8250 kg	8900 kg	DN200

Scala-Scale	Data-Date	Dis.to-Drawn	N°Pezzi
	23/09/16	B.P.	
Peso-Weight Kg.	Materiali-Materials		
Denominazione-Denomination			
WATER CHILLERS mod. SBSF.840÷1030/CS.ST.NT.NP.			
Particolare-Detail			
Overall dimension - Lift Instruction			
REFRIGERANT R410a			



DIS.-DRAW N.	DIM-SBSF-840ST01
Rev.	01 - B.P. - 08/08/18
PROGRAM.N.	