

## Corrective factors for Duty and for Compressor Absorbed Power - EET/EEF Chillers

### General notes for all tables:

**Chiller Cooling Capacity (AT, LWT) = CD (AT, LWT) x Nominal Cooling Capacity**  
**Compressor Absorbed Power (AT, LWT) = CP (AT, LWT) x Nominal Absorbed Power**

Where:  
AT = ambient temperature  
LWT = leaving water temperature  
CP= corrective factor for compressor assorbed power  
CD = corrective factor for duty.

- Operating range for standard EET/EEF chillers
- Add optional LW
- Add TR45 option
- Add TR45 and LW options

ATTENTION: add GL50 or GL50D option with glycol percentage over 30%

The values in the tables are referred to:

- condenser with aluminium fin without coating and without filter on the condenser
- Elevation < 500m
- EWT-LWT = 5°C, a different value for this parameter requires verification of pressure drop and pumps from technical department

**CD - Corrective factors for Duty - EET/EEF Chillers - Water**

CD	Leaving Water Temperature (LWT) [°C]																										
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
20																1.01	1.04	1.08	1.12	1.15	1.18	1.23	1.26	1.30	1.34	1.38	1.42
21																1.01	1.04	1.08	1.12	1.15	1.18	1.23	1.26	1.30	1.34	1.38	1.42
22																1.01	1.04	1.08	1.12	1.15	1.18	1.23	1.26	1.30	1.34	1.38	1.42
23																1.01	1.04	1.08	1.12	1.15	1.18	1.23	1.26	1.30	1.34	1.38	1.42
24																1.01	1.04	1.08	1.12	1.15	1.18	1.23	1.26	1.30	1.33	1.37	1.41
25																1.01	1.04	1.08	1.12	1.15	1.18	1.22	1.25	1.29	1.33	1.36	1.40
26																1.01	1.04	1.08	1.11	1.14	1.17	1.21	1.24	1.28	1.32	1.35	1.39
27																1.00	1.04	1.07	1.10	1.13	1.17	1.20	1.24	1.27	1.31	1.34	1.38
28																1.00	1.03	1.06	1.09	1.13	1.16	1.19	1.23	1.26	1.30	1.33	1.37
29																0.99	1.02	1.05	1.08	1.12	1.15	1.18	1.22	1.25	1.29	1.32	1.36
30																0.98	1.01	1.04	1.08	1.11	1.14	1.17	1.21	1.24	1.28	1.32	1.35
31																0.97	1.00	1.04	1.07	1.10	1.13	1.16	1.20	1.23	1.27	1.31	1.34
32																0.97	1.00	1.03	1.06	1.09	1.12	1.16	1.19	1.22	1.26	1.29	1.33
33																0.96	0.99	1.02	1.05	1.08	1.11	1.15	1.18	1.21	1.25	1.28	1.32
34																0.95	0.98	1.01	1.04	1.07	1.10	1.14	1.17	1.20	1.24	1.27	1.31
35																0.94	0.97	1.00	1.03	1.06	1.09	1.12	1.16	1.19	1.23	1.26	1.30
36																0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.15	1.18	1.21	1.25	1.28
37																0.92	0.95	0.98	1.01	1.04	1.07	1.10	1.13	1.17	1.20	1.23	1.27
38																0.91	0.94	0.97	0.99	1.03	1.06	1.09	1.12	1.15	1.18	1.22	1.25
39																0.90	0.93	0.95	0.98	1.02	1.04	1.07	1.11	1.14	1.17	1.20	1.24
40																0.89	0.92	0.94	0.97	1.00	1.03	1.06	1.09	1.13	1.15	1.19	1.22
41																0.87	0.90	0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.14	1.17	1.21
42																0.86	0.89	0.92	0.95	0.98	1.01	1.03	1.07	1.10	1.13	1.16	1.19
43																0.85	0.88	0.91	0.93	0.96	0.99	1.02	1.05	1.08	1.11		
44																0.84	0.87	0.89	0.92	0.95	0.98	1.01					
45																0.83	0.85	0.88	0.91	0.94							

**CP - Corrective factors for Compressor Absorbed Power - EET/EEF Chillers - Water**

CP	Leaving Water Temperature (LWT) [°C]																										
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
20																0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
21																0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
22																0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
23																0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
24																0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.84	0.86
25																0.79	0.80	0.80	0.80	0.81	0.81	0.83	0.84	0.85	0.86	0.88	0.89
26																0.79	0.80	0.80	0.81	0.82	0.84	0.85	0.86	0.87	0.88	0.90	0.91
27																0.81	0.82	0.82	0.83	0.84	0.85	0.87	0.88	0.89	0.90	0.92	0.93
28																0.83	0.83	0.84	0.85	0.86	0.87	0.89	0.90	0.91	0.92	0.94	0.95
29																0.85	0.85	0.86	0.87	0.88	0.89	0.91	0.92	0.93	0.95	0.96	0.98
30																0.87	0.87	0.88	0.89	0.90	0.92	0.93	0.94	0.95	0.97	0.98	1.00
31																0.89	0.89	0.90	0.91	0.92	0.94	0.95	0.96	0.98	0.99	1.00	1.02
32																0.91	0.91	0.92	0.93	0.95	0.96	0.97	0.99	1.00	1.01	1.03	1.04
33																0.93	0.93	0.94	0.96	0.97	0.98	0.99	1.01	1.02	1.04	1.05	1.07
34																0.95	0.95	0.97	0.98	0.99	1.00	1.02	1.03	1.04	1.06	1.07	1.09
35																0.97	0.98	0.99	1.00	1.01	1.03	1.04	1.05	1.07	1.08	1.10	1.12
36																0.99	1.00	1.01	1.02	1.04	1.05	1.06	1.08	1.10	1.11	1.12	1.14
37																1.02	1.02	1.03	1.05	1.06	1.07	1.09	1.10	1.12	1.14	1.15	1.17
38																1.04	1.05	1.06	1.07	1.09	1.10	1.11	1.13	1.14	1.16	1.18	1.20
39																1.06	1.07	1.08	1.10	1.11	1.13	1.14	1.15	1.17	1.18	1.20	1.22
40																1.09	1.09	1.11	1.12	1.14	1.15	1.17	1.18	1.20	1.22	1.24	1.25
41																1.11	1.12	1.13	1.15	1.17	1.18	1.19	1.21	1.23	1.24	1.26	1.27
42																1.14	1.15	1.16	1.18	1.19	1.21	1.22	1.24	1.25	1.27	1.28	1.30
43																1.17	1.18	1.19	1.20	1.22	1.23	1.25	1.27	1.28	1.30		
44																1.19	1.20	1.22	1.23	1.25	1.26	1.28					
45																1.22	1.23	1.24	1.26	1.28							

**CD - Corrective factors for Duty - EET/EEF Chillers - 20% Ethylene Glycol**

CD	Leaving Water Temperature (LWT) [°C]																											
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	
20										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
21										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
22										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
23										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
24										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
25										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.80	0.81	0.82	0.83	0.84	0.85	0.86	0.88	0.89
26										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.81	0.82	0.84	0.85	0.86	0.87	0.88	0.90	0.91
27										0.74	0.74	0.74	0.75	0.76	0.76	0.79	0.80	0.82	0.82	0.83	0.84	0.85	0.87	0.88	0.89	0.90	0.92	0.93
28										0.74	0.74	0.76	0.77	0.78	0.79	0.80	0.81	0.83	0.84	0.85	0.86	0.87	0.89	0.90	0.91	0.92	0.94	0.95
29										0.75	0.77	0.78	0.79	0.80	0.81	0.82	0.84	0.85	0.86	0.87	0.88	0.89	0.91	0.92	0.93	0.95	0.96	0.98
30										0.77	0.78	0.79	0.80	0.82	0.83	0.84	0.85	0.87	0.88	0.89	0.90	0.92	0.93	0.94	0.95	0.97	0.98	1.00
31										0.79	0.80	0.81	0.82	0.84	0.85	0.86	0.87	0.89	0.90	0.91	0.92	0.94	0.95	0.96	0.98	0.99	1.00	1.02
32										0.81	0.82	0.83	0.84	0.85	0.87	0.88	0.89	0.91	0.92	0.93	0.95	0.96	0.97	0.99	1.00	1.01	1.03	1.04
33										0.82	0.84	0.85	0.86	0.88	0.89	0.90	0.91	0.94	0.96	0.97	0.98	0.99	1.01	1.02	1.04	1.05	1.07	1.09
34										0.84	0.86	0.87	0.88	0.90	0.91	0.92	0.94	0.95	0.97	0.98	0.99	1.00	1.02	1.03	1.04	1.06	1.07	1.09
35										0.86	0.88	0.89	0.90	0.92	0.93	0.94	0.96	0.98	0.99	1.00	1.01	1.03	1.04	1.05	1.07	1.08	1.10	1.12
36										0.88	0.90	0.91	0.92	0.94	0.95	0.97	0.98	1.00	1.01	1.02	1.04	1.05	1.06	1.08	1.10	1.12	1.14	1.16
37										0.90	0.92	0.93	0.94	0.96	0.97	0.99	1.00	1.02	1.03	1.05	1.06	1.07	1.09	1.10	1.12	1.14	1.15	1.17
38										0.93	0.94	0.95	0.96	0.98	1.00	1.01	1.03	1.05	1.06	1.07	1.09	1.10	1.12	1.14	1.16	1.18	1.20	
39										0.95	0.96	0.98	0.99	1.00	1.02	1.03	1.05	1.07	1.08	1.10	1.11	1.13	1.14	1.15	1.17	1.18	1.20	1.22
40										0.97	0.98	1.00	1.01	1.03	1.04	1.06	1.07	1.09	1.11	1.12	1.14	1.15	1.17	1.18	1.20	1.21	1.23	1.25
41										0.99	1.01	1.02	1.03	1.05	1.07	1.08	1.10	1.12	1.13	1.15	1.17	1.18	1.19	1.21	1.23	1.24	1.26	1.27
42										1.01	1.03	1.04	1.06	1.08	1.09	1.11	1.12	1.15	1.16	1.18	1.19	1.21	1.22	1.24	1.25	1.27	1.28	1.30
43										1.04	1.06	1.07	1.08	1.10	1.12	1.13	1.15	1.16	1.18	1.19	1.20	1.22	1.23	1.25	1.26	1.28		
44										1.06	1.08	1.09	1.11	1.13	1.14	1.16	1.18	1.20	1.22	1.23	1.25	1.26	1.28					
45										1.09	1.10	1.12	1.14	1.15	1.17	1.18	1.20	1.23	1.24	1.26	1.28							

**CP - Corrective factors for Compressor Absorbed Power - EET/EEF Chillers - 20% Ethylene Glycol**

CP	Leaving Water Temperature (LWT) [°C]																											
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	
20										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
21										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
22										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
23										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.82	0.83	0.85
24										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.80	0.81	0.81	0.81	0.82	0.82	0.83	0.84	0.87
25										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.80	0.81	0.82	0.83	0.84	0.85	0.86	0.88	0.89
26										0.74	0.74	0.74	0.75	0.76	0.76	0.77	0.78	0.80	0.80	0.81	0.82	0.84	0.85	0.86	0.87	0.88	0.90	0.91
27										0.74	0.74	0.74	0.75	0.76	0.76	0.79	0.80	0.82	0.82	0.83	0.84	0.85	0.87	0.88	0.89	0.90	0.92	0.93
28										0.74	0.74	0.76	0.77	0.78	0.79	0.80	0.81	0.83	0.84	0.85	0.86	0.87	0.89	0.90	0.91	0.92	0.94	0.95
29										0.75	0.77	0.78	0.79	0.80	0.81	0.82	0.84	0.85	0.86	0.87	0.88	0.89	0.91	0.92	0.93	0.95	0.96	0.98
30										0.77	0.78	0.79	0.80	0.82	0.83	0.84	0.85	0.87	0.88	0.89	0.90	0.92	0.93	0.94	0.95	0.97	0.98	1.00
31										0.79	0.80	0.81	0.82	0.84	0.85	0.86	0.87	0.89	0.90	0.91	0.92	0.94	0.95	0.96	0.98	0.99	1.00	1.02
32										0.81	0.82	0.83	0.84	0.85	0.87	0.88	0.89	0.91	0.92	0.93	0.95	0.96	0.97	0.99	1.00	1.01	1.03	1.04
33										0.82	0.84	0.85	0.86	0.88	0.89	0.90	0.91	0.93	0.94	0.96	0.97	0.98	0.99	1.01	1.02	1.04	1.05	1.07
34										0.84	0.86	0.87	0.88	0.90	0.91	0.92	0.94	0.95	0.97	0.98	0.99	1.00	1.01	1.03	1.04	1.06	1.07	1.09
35										0.86	0.88	0.89	0.90	0.92	0.93	0.94	0.96	0.98	0.99	1.00	1.01	1.03	1.04	1.05	1.07	1.08	1.10	1.12
36										0.88	0.90	0.91	0.92	0.94	0.95	0.97	0.98	1.00	1.01	1.02	1.04	1.05	1.06	1.08	1.10	1.11	1.12	1.14
37		</																										

**CD - Corrective factors for Duty - EET/EEF Chillers - 30% Ethylene Glycol**

CD	Leaving Water Temperature (LWT) [°C]																										
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
20						0.64	0.67	0.69	0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.13	1.17	1.21	1.24	1.29	1.32	1.36
21						0.64	0.67	0.69	0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.13	1.17	1.21	1.24	1.29	1.32	1.36
22						0.64	0.67	0.69	0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.13	1.17	1.21	1.24	1.29	1.32	1.36
23						0.64	0.67	0.69	0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.13	1.17	1.21	1.24	1.29	1.32	1.36
24						0.64	0.67	0.69	0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.13	1.17	1.21	1.24	1.28	1.31	1.35
25						0.64	0.67	0.69	0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.13	1.17	1.20	1.24	1.27	1.31	1.34
26						0.64	0.67	0.69	0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.06	1.10	1.13	1.16	1.19	1.23	1.26	1.30	1.33
27						0.64	0.67	0.69	0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.96	0.99	1.02	1.05	1.09	1.12	1.15	1.18	1.22	1.25	1.29	1.32
28						0.64	0.67	0.69	0.73	0.76	0.79	0.82	0.85	0.89	0.92	0.95	0.99	1.02	1.05	1.08	1.11	1.14	1.18	1.21	1.25	1.28	1.31
29						0.64	0.67	0.69	0.72	0.75	0.78	0.81	0.85	0.88	0.91	0.94	0.98	1.01	1.04	1.07	1.10	1.14	1.17	1.20	1.24	1.27	1.31
30						0.64	0.66	0.68	0.72	0.75	0.78	0.81	0.84	0.87	0.91	0.94	0.97	1.00	1.03	1.06	1.10	1.13	1.16	1.19	1.22	1.26	1.30
31						0.63	0.66	0.68	0.71	0.74	0.77	0.80	0.83	0.87	0.90	0.93	0.97	0.99	1.02	1.05	1.09	1.12	1.15	1.18	1.22	1.25	1.29
32						0.63	0.65	0.67	0.70	0.73	0.76	0.79	0.83	0.86	0.89	0.92	0.96	0.99	1.02	1.05	1.08	1.11	1.14	1.17	1.21	1.24	1.28
33						0.62	0.64	0.66	0.70	0.72	0.75	0.79	0.82	0.85	0.88	0.91	0.95	0.98	1.01	1.04	1.07	1.10	1.13	1.16	1.20	1.23	1.27
34						0.61	0.63	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.91	0.94	0.97	1.00	1.03	1.06	1.09	1.12	1.15	1.18	1.22	1.25
35						0.60	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.90	0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.14	1.17	1.21	1.24
36						0.60	0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.89	0.92	0.95	0.98	1.01	1.03	1.07	1.10	1.13	1.16	1.19	1.23
37						0.59	0.61	0.64	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.91	0.94	0.96	0.99	1.02	1.05	1.08	1.12	1.15	1.18	1.21
38						0.58	0.61	0.63	0.66	0.68	0.71	0.74	0.77	0.80	0.84	0.86	0.90	0.93	0.95	0.98	1.01	1.04	1.07	1.10	1.14	1.17	1.20
39						0.58	0.60	0.62	0.65	0.68	0.71	0.74	0.76	0.79	0.83	0.85	0.89	0.91	0.94	0.97	1.00	1.03	1.06	1.09	1.12	1.15	1.18
40						0.57	0.59	0.61	0.64	0.67	0.70	0.73	0.75	0.78	0.81	0.85	0.87	0.90	0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.14	1.17
41						0.56	0.58	0.61	0.63	0.66	0.69	0.72	0.74	0.77	0.80	0.83	0.86	0.89	0.92	0.95	0.98	1.01	1.03	1.06	1.09	1.12	1.15
42						0.55	0.58	0.60	0.62	0.65	0.68	0.71	0.73	0.77	0.79	0.82	0.85	0.88	0.91	0.94	0.96	0.99	1.02	1.05	1.08	1.11	1.14
43						0.55	0.57	0.59	0.62	0.64	0.67	0.70	0.72	0.75	0.78	0.81	0.84	0.87	0.90	0.92	0.95	0.98	1.01	1.03	1.06		
44						0.54	0.56	0.58	0.61	0.63	0.66	0.69	0.71	0.74	0.77	0.80	0.83	0.86	0.88	0.91	0.94	0.97					
45						0.53	0.55	0.57	0.60	0.62	0.65	0.68	0.71	0.73	0.76	0.79	0.82	0.84	0.87	0.90							

**CP - Corrective factors for Compressor Absorbed Power - EET/EEF Chillers - 30% Ethylene Glycol**

CP	Leaving Water Temperature (LWT) [°C]																										
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
20						0.72	0.72	0.72	0.73	0.74	0.74	0.75	0.75	0.75	0.76	0.78	0.79	0.79	0.79	0.80	0.80	0.80	0.82	0.82	0.82	0.83	0.84
21						0.72	0.72	0.72	0.73	0.74	0.74	0.75	0.75	0.75	0.76	0.78	0.79	0.79	0.79	0.80	0.80	0.80	0.82	0.82	0.82	0.83	0.84
22						0.72	0.72	0.72	0.73	0.74	0.74	0.75	0.75	0.75	0.76	0.78	0.79	0.79	0.79	0.80	0.80	0.80	0.82	0.82	0.82	0.83	0.84
23						0.72	0.72	0.72	0.73	0.74	0.74	0.75	0.75	0.75	0.76	0.78	0.79	0.79	0.80	0.80	0.80	0.82	0.82	0.82	0.83	0.84	
24						0.72	0.72	0.72	0.73	0.74	0.74	0.75	0.75	0.75	0.76	0.78	0.79	0.79	0.80	0.80	0.80	0.82	0.82	0.82	0.84	0.85	
25						0.72	0.72	0.72	0.73	0.74	0.74	0.75	0.75	0.75	0.76	0.78	0.79	0.79	0.80	0.80	0.80	0.82	0.84	0.85	0.86	0.87	
26						0.72	0.72	0.72	0.73	0.74	0.74	0.75	0.75	0.75	0.76	0.78	0.79	0.79	0.81	0.82	0.83	0.84	0.86	0.87	0.88	0.89	
27						0.72	0.72	0.72	0.73	0.74	0.74	0.75	0.75	0.77	0.78	0.79	0.81	0.82	0.83	0.84	0.85	0.86	0.88	0.90	0.91	0.93	
28						0.72	0.72	0.72	0.73	0.74	0.75	0.76	0.78	0.79	0.80	0.81	0.83	0.84	0.85	0.86	0.87	0.88	0.90	0.91	0.92	0.93	
29						0.72	0.72	0.74	0.75	0.76	0.77	0.78	0.79	0.81	0.82	0.83	0.85	0.86	0.87	0.88	0.89	0.90	0.92	0.93	0.94	0.96	
30						0.74	0.75	0.76	0.77	0.78	0.79	0.80	0.81	0.82	0.84	0.85	0.87	0.88	0.89	0.90	0.91	0.92	0.93	0.95	0.96	0.98	
31						0.76	0.76	0.77	0.78	0.80	0.81	0.82	0.83	0.84	0.86	0.87	0.89	0.90	0.91	0.92	0.93	0.95	0.96	0.97	0.98	1.00	
32						0.77	0.78	0.79	0.80	0.81	0.83	0.84	0.85	0.86	0.88	0.89	0.91	0.92	0.93	0.94	0.95	0.97	0.98	0.99	1.01	1.02	
33						0.79	0.80	0.81	0.82	0.83	0.84	0.86	0.87	0.88	0.90	0.91	0.93	0.94	0.95	0.96	0.97	0.99	1.00	1.02	1.03	1.05	
34						0.81	0.82	0.83	0.84	0.85	0.86	0.88	0.89	0.90	0.92	0.93	0.94	0.95	0.96	0.97	0.99	1.00	1.01	1.03	1.04	1.05	
35						0.83	0.84	0.85</td																			

**CD - Corrective factors for Duty - EET/EEF Chillers - 40% Ethylene Glycol**

CD	Leaving Water Temperature (LWT) [°C]																										
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
20						0.63	0.66	0.69	0.72	0.75	0.78	0.82	0.85	0.89	0.92	0.96	0.99	1.02	1.06	1.09	1.12	1.16	1.20	1.23	1.27	1.31	1.35
21						0.63	0.66	0.69	0.72	0.75	0.78	0.82	0.85	0.89	0.92	0.96	0.99	1.02	1.06	1.09	1.12	1.16	1.20	1.23	1.27	1.31	1.35
22						0.63	0.66	0.69	0.72	0.75	0.78	0.82	0.85	0.89	0.92	0.96	0.99	1.02	1.06	1.09	1.12	1.16	1.20	1.23	1.27	1.31	1.35
23						0.63	0.66	0.69	0.72	0.75	0.78	0.82	0.85	0.89	0.92	0.96	0.99	1.02	1.06	1.09	1.12	1.16	1.20	1.23	1.27	1.31	1.35
24						0.63	0.66	0.69	0.72	0.75	0.78	0.82	0.85	0.89	0.92	0.96	0.99	1.02	1.06	1.09	1.12	1.16	1.20	1.23	1.27	1.30	1.34
25						0.63	0.66	0.69	0.72	0.75	0.78	0.82	0.85	0.89	0.92	0.96	0.99	1.02	1.06	1.09	1.12	1.16	1.19	1.23	1.26	1.29	1.33
26						0.63	0.66	0.69	0.72	0.75	0.78	0.82	0.85	0.89	0.92	0.96	0.99	1.02	1.06	1.09	1.12	1.15	1.18	1.22	1.25	1.29	1.32
27						0.63	0.66	0.69	0.72	0.75	0.78	0.82	0.85	0.88	0.91	0.95	0.98	1.01	1.05	1.08	1.11	1.14	1.17	1.21	1.24	1.28	1.31
28						0.63	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.91	0.94	0.98	1.01	1.04	1.07	1.10	1.13	1.17	1.20	1.23	1.27	1.30
29						0.63	0.66	0.68	0.71	0.74	0.77	0.80	0.84	0.87	0.90	0.94	0.97	1.00	1.03	1.06	1.09	1.13	1.16	1.19	1.23	1.26	1.29
30						0.63	0.65	0.67	0.70	0.74	0.77	0.80	0.83	0.86	0.89	0.93	0.96	0.99	1.02	1.06	1.09	1.12	1.15	1.18	1.22	1.25	1.28
31						0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.89	0.92	0.95	0.98	1.01	1.05	1.08	1.11	1.14	1.17	1.20	1.24	1.28
32						0.61	0.64	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.88	0.91	0.94	0.98	1.01	1.04	1.07	1.10	1.13	1.16	1.20	1.23	1.26
33						0.61	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.84	0.87	0.90	0.93	0.97	1.00	1.03	1.06	1.09	1.12	1.15	1.19	1.22	1.25
34						0.60	0.63	0.65	0.68	0.70	0.73	0.77	0.80	0.83	0.86	0.89	0.92	0.96	0.99	1.02	1.05	1.08	1.11	1.14	1.17	1.20	1.24
35						0.60	0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.88	0.92	0.95	0.98	1.01	1.04	1.07	1.10	1.13	1.16	1.19	1.23
36						0.59	0.61	0.63	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.91	0.94	0.97	1.00	1.02	1.06	1.09	1.12	1.15	1.18	1.21
37						0.58	0.60	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.90	0.93	0.96	0.98	1.01	1.04	1.07	1.10	1.14	1.17	1.20
38						0.57	0.60	0.62	0.65	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.89	0.92	0.94	0.97	1.00	1.03	1.06	1.09	1.12	1.16	1.19
39						0.57	0.59	0.61	0.64	0.67	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.91	0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.14	1.17
40						0.56	0.58	0.60	0.63	0.66	0.69	0.71	0.74	0.77	0.80	0.83	0.86	0.89	0.92	0.95	0.98	1.01	1.04	1.07	1.10	1.13	1.16
41						0.55	0.58	0.60	0.62	0.65	0.68	0.70	0.73	0.76	0.79	0.82	0.86	0.88	0.91	0.94	0.96	0.99	1.02	1.05	1.08	1.11	1.14
42						0.55	0.57	0.59	0.61	0.64	0.67	0.70	0.72	0.75	0.78	0.81	0.84	0.87	0.90	0.92	0.95	0.98	1.01	1.04	1.07	1.10	1.13
43						0.54	0.56	0.58	0.61	0.63	0.66	0.69	0.72	0.75	0.77	0.80	0.83	0.86	0.89	0.91	0.94	0.97	1.00	1.03	1.05		
44						0.53	0.55	0.57	0.60	0.62	0.65	0.68	0.71	0.73	0.76	0.79	0.82	0.85	0.87	0.90	0.93	0.96					
45						0.52	0.54	0.56	0.59	0.62	0.64	0.67	0.70	0.72	0.75	0.78	0.81	0.84	0.86	0.89							

**CP - Corrective factors for Compressor Absorbed Power - EET/EEF Chillers - 40% Ethylene Glycol**

CP	Leaving Water Temperature (LWT) [°C]																										
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
20						0.64	0.66	0.69	0.72	0.73	0.73	0.74	0.75	0.76	0.76	0.77	0.79	0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.83	0.84	
21						0.64	0.66	0.69	0.72	0.73	0.73	0.74	0.75	0.76	0.76	0.77	0.79	0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.83	0.84	
22						0.64	0.66	0.69	0.72	0.73	0.73	0.74	0.75	0.76	0.76	0.77	0.79	0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.83	0.84	
23						0.64	0.66	0.69	0.72	0.73	0.73	0.74	0.75	0.76	0.76	0.77	0.79	0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.83	0.84	
24						0.64	0.66	0.69	0.72	0.73	0.73	0.74	0.75	0.76	0.76	0.77	0.79	0.79	0.80	0.80	0.80	0.81	0.81	0.84	0.85	0.86	
25						0.64	0.66	0.69	0.72	0.73	0.73	0.74	0.75	0.76	0.76	0.77	0.79	0.79	0.80	0.80	0.80	0.82	0.83	0.84	0.86	0.87	0.88
26						0.64	0.66	0.69	0.72	0.73	0.73	0.74	0.75	0.76	0.76	0.77	0.79	0.79	0.81	0.82	0.83	0.84	0.85	0.86	0.88	0.89	0.90
27						0.64	0.66	0.69	0.72	0.73	0.73	0.74	0.75	0.76	0.76	0.77	0.79	0.80	0.80	0.80	0.80	0.81	0.81	0.81	0.83	0.84	
28						0.64	0.66	0.69	0.72	0.73	0.75	0.76	0.77	0.78	0.80	0.81	0.83	0.85	0.86	0.87	0.88	0.89	0.90	0.92	0.93	0.94	
29						0.64	0.66	0.68	0.71	0.74	0.77	0.78	0.79	0.80	0.81	0.82	0.85	0.86	0.88	0.89	0.90	0.91	0.92	0.94	0.95	0.97	
30						0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.81	0.82	0.83	0.85	0.87	0.88	0.89	0.90	0.91	0.92	0.93	0.94	0.96	0.97	0.99
31						0.63	0.65	0.67	0.70	0.73	0.76	0.79	0.82	0.84	0.85	0.87	0.89	0.90	0.91	0.92	0.93	0.94	0.95	0.97	0.98	1.00	1.01
32						0.62	0.64	0.67	0.69	0.72	0.75	0.78	0.82	0.85	0.87	0.89	0.91	0.92	0.93	0.94	0.95	0.96	0.98	0.99	1.00	1.02	1.03
33						0.61	0.64	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.91	0.92	0.94	0.95	0.96	0.97	0.99	1.00	1.01	1.03	1.04	1.06
34						0.61	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.87	0.90	0.95	0.96	0.97	0.98	1.00	1.01	1.02	1.03	1.05	1.07	1.08
35						0.60</																					

**CD - Corrective factors for Duty - EET/EEF Chillers - 50% Ethylene Glycol**

CD	Leaving Water Temperature (LWT) [°C]																									
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
20					0.62	0.65	0.67	0.70	0.73	0.77	0.80	0.84	0.87	0.91	0.94	0.98	1.01	1.05	1.08	1.11	1.15	1.18	1.22	1.26	1.30	1.33
21					0.62	0.65	0.67	0.70	0.73	0.77	0.80	0.84	0.87	0.91	0.94	0.98	1.01	1.05	1.08	1.11	1.15	1.18	1.22	1.26	1.30	1.33
22					0.62	0.65	0.67	0.70	0.73	0.77	0.80	0.84	0.87	0.91	0.94	0.98	1.01	1.05	1.08	1.11	1.15	1.18	1.22	1.26	1.30	1.33
23					0.62	0.65	0.67	0.70	0.73	0.77	0.80	0.84	0.87	0.91	0.94	0.98	1.01	1.05	1.08	1.11	1.15	1.18	1.22	1.26	1.30	1.33
24					0.62	0.65	0.67	0.70	0.73	0.77	0.80	0.84	0.87	0.91	0.94	0.98	1.01	1.05	1.08	1.11	1.15	1.18	1.22	1.26	1.29	1.33
25					0.62	0.65	0.67	0.70	0.73	0.77	0.80	0.84	0.87	0.91	0.94	0.98	1.01	1.05	1.08	1.11	1.15	1.18	1.21	1.25	1.28	1.32
26					0.62	0.65	0.67	0.70	0.73	0.77	0.80	0.84	0.87	0.91	0.94	0.98	1.01	1.04	1.07	1.11	1.14	1.17	1.20	1.24	1.27	1.31
27					0.62	0.65	0.67	0.70	0.73	0.77	0.80	0.84	0.87	0.90	0.94	0.97	1.00	1.03	1.07	1.10	1.13	1.16	1.20	1.23	1.27	1.30
28					0.62	0.65	0.67	0.70	0.73	0.77	0.80	0.83	0.86	0.90	0.93	0.96	1.00	1.03	1.06	1.09	1.12	1.16	1.19	1.22	1.26	1.29
29					0.62	0.65	0.67	0.70	0.73	0.76	0.79	0.82	0.86	0.89	0.92	0.95	0.99	1.02	1.05	1.08	1.12	1.15	1.18	1.22	1.26	1.28
30					0.62	0.64	0.66	0.69	0.72	0.75	0.78	0.82	0.85	0.88	0.91	0.95	0.98	1.01	1.04	1.07	1.11	1.14	1.17	1.20	1.24	1.27
31					0.61	0.63	0.66	0.68	0.71	0.74	0.78	0.81	0.84	0.87	0.91	0.94	0.97	1.00	1.03	1.06	1.10	1.13	1.16	1.19	1.23	1.26
32					0.61	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.90	0.93	0.96	0.99	1.02	1.05	1.09	1.12	1.15	1.18	1.22	1.25
33					0.60	0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.86	0.89	0.92	0.95	0.98	1.01	1.04	1.08	1.11	1.14	1.17	1.20	1.24
34					0.59	0.61	0.64	0.66	0.69	0.72	0.75	0.78	0.81	0.85	0.88	0.91	0.94	0.97	1.00	1.03	1.06	1.10	1.13	1.16	1.19	1.23
35					0.59	0.61	0.63	0.65	0.68	0.71	0.74	0.77	0.81	0.84	0.87	0.90	0.93	0.97	0.99	1.02	1.05	1.08	1.12	1.15	1.18	1.21
36					0.58	0.60	0.62	0.65	0.68	0.70	0.74	0.76	0.80	0.83	0.86	0.89	0.93	0.95	0.98	1.01	1.04	1.07	1.10	1.13	1.17	1.20
37					0.57	0.59	0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.88	0.92	0.94	0.97	1.00	1.03	1.06	1.09	1.12	1.16	1.19
38					0.57	0.59	0.61	0.63	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.90	0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.14	1.17
39					0.56	0.58	0.60	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.89	0.92	0.95	0.98	1.01	1.04	1.07	1.10	1.13	1.16
40					0.55	0.57	0.59	0.62	0.64	0.68	0.70	0.73	0.76	0.79	0.82	0.85	0.88	0.91	0.94	0.97	1.00	1.02	1.05	1.08	1.11	1.14
41					0.54	0.57	0.59	0.61	0.64	0.67	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.90	0.93	0.95	0.98	1.01	1.04	1.07	1.10	1.13
42					0.54	0.56	0.58	0.60	0.63	0.66	0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.89	0.91	0.94	0.97	1.00	1.03	1.06	1.09	1.11
43					0.53	0.55	0.57	0.59	0.62	0.65	0.67	0.69	0.72	0.75	0.78	0.81	0.84	0.86	0.89	0.92	0.94					
44					0.52	0.54	0.56	0.58	0.61	0.64	0.67	0.69	0.72	0.75	0.78	0.81	0.84	0.86	0.89	0.92	0.94					
45					0.51	0.53	0.55	0.58	0.60	0.63	0.66	0.68	0.71	0.74	0.77	0.80	0.82	0.85	0.88							

**CP - Corrective factors for Compressor Absorbed Power - EET/EEF Chillers - 50% Ethylene Glycol**

CP	Leaving Water Temperature (LWT) [°C]																									
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
20					0.63	0.65	0.68	0.70	0.72	0.73	0.74	0.74	0.74	0.75	0.77	0.78	0.78	0.79	0.79	0.79	0.80	0.81	0.81	0.81	0.82	0.83
21					0.63	0.65	0.68	0.70	0.72	0.73	0.74	0.74	0.74	0.75	0.77	0.78	0.78	0.79	0.79	0.80	0.81	0.81	0.81	0.82	0.83	
22					0.63	0.65	0.68	0.70	0.72	0.73	0.74	0.74	0.74	0.75	0.77	0.78	0.78	0.79	0.79	0.80	0.81	0.81	0.81	0.82	0.83	
23					0.63	0.65	0.68	0.70	0.72	0.73	0.74	0.74	0.74	0.75	0.77	0.78	0.78	0.79	0.79	0.80	0.81	0.81	0.81	0.82	0.83	
24					0.63	0.65	0.68	0.70	0.72	0.73	0.74	0.74	0.74	0.75	0.77	0.78	0.78	0.79	0.79	0.80	0.81	0.82	0.83	0.84	0.86	
25					0.63	0.65	0.68	0.70	0.72	0.73	0.74	0.74	0.74	0.75	0.77	0.78	0.78	0.79	0.79	0.81	0.82	0.83	0.84	0.85	0.86	
26					0.63	0.65	0.68	0.70	0.72	0.73	0.74	0.74	0.74	0.75	0.77	0.78	0.78	0.79	0.81	0.82	0.83	0.85	0.86	0.87	0.88	
27					0.63	0.65	0.68	0.70	0.72	0.73	0.74	0.74	0.74	0.76	0.77	0.79	0.80	0.82	0.83	0.84	0.85	0.87	0.88	0.90	0.91	
28					0.63	0.65	0.68	0.70	0.72	0.75	0.76	0.77	0.78	0.79	0.80	0.82	0.83	0.84	0.85	0.86	0.87	0.89	0.90	0.91	0.92	
29					0.63	0.65	0.67	0.70	0.73	0.76	0.77	0.79	0.80	0.81	0.82	0.84	0.85	0.86	0.87	0.88	0.89	0.91	0.92	0.93	0.95	
30					0.62	0.64	0.67	0.69	0.72	0.75	0.79	0.80	0.81	0.83	0.84	0.86	0.88	0.89	0.90	0.91	0.92	0.94	0.95	0.96	0.97	
31					0.62	0.64	0.66	0.69	0.72	0.75	0.78	0.81	0.83	0.85	0.86	0.88	0.89	0.90	0.91	0.92	0.94	0.95	0.96	0.97	0.99	
32					0.61	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.87	0.88	0.90	0.91	0.92	0.93	0.95	0.96	0.97	0.98	1.00	1.01	
33					0.61	0.63	0.65	0.67	0.70	0.74	0.77	0.80	0.83	0.86	0.89	0.92	0.93	0.94	0.96	0.97	0.98	0.99	1.01	1.02	1.04	
34					0.60	0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.89	0.94	0.95	0.97	0.98	0.99	1.00	1.01	1.03	1.04	1.06	
35					0.59	0.61	0.64	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.88	0.97	0.98	0.99	1.00	1.01	1.03	1.04	1.05	1.07	1.08	
36					0.59	0.61	0.63	0.66	0.69	0.71	0.74															

**CD - Corrective factors for Duty - EET/EEF Chillers - 20% Propylene Glycol**

CD	Leaving Water Temperature (LWT) [°C]																											
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	
20										0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.14	1.18	1.21	1.24	1.29	1.32	1.36
21										0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.14	1.18	1.21	1.24	1.29	1.32	1.36
22										0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.14	1.18	1.21	1.24	1.29	1.32	1.36
23										0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.14	1.18	1.21	1.24	1.29	1.32	1.36
24										0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.14	1.18	1.21	1.24	1.28	1.32	1.35
25										0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.14	1.17	1.20	1.24	1.27	1.31	1.34
26										0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.97	1.00	1.03	1.07	1.10	1.13	1.16	1.20	1.23	1.26	1.30	1.34
27										0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.96	1.00	1.03	1.06	1.09	1.12	1.16	1.19	1.22	1.25	1.29	1.33
28										0.73	0.76	0.79	0.82	0.85	0.89	0.92	0.96	0.99	1.02	1.05	1.08	1.11	1.15	1.18	1.21	1.25	1.28	1.32
29										0.72	0.75	0.78	0.81	0.85	0.88	0.91	0.95	0.98	1.01	1.04	1.07	1.10	1.14	1.17	1.20	1.24	1.27	1.31
30										0.72	0.75	0.78	0.81	0.84	0.87	0.91	0.94	0.97	1.00	1.04	1.07	1.10	1.13	1.16	1.20	1.23	1.26	1.30
31										0.71	0.74	0.77	0.80	0.83	0.87	0.90	0.93	0.97	1.00	1.03	1.06	1.09	1.12	1.15	1.19	1.22	1.25	1.29
32										0.70	0.73	0.76	0.79	0.83	0.86	0.89	0.92	0.96	0.99	1.02	1.05	1.08	1.11	1.14	1.18	1.21	1.24	1.28
33										0.70	0.73	0.76	0.79	0.82	0.85	0.88	0.91	0.95	0.98	1.01	1.04	1.07	1.10	1.13	1.17	1.20	1.23	1.27
34										0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.91	0.94	0.97	1.00	1.03	1.06	1.09	1.12	1.15	1.19	1.22	1.25
35										0.68	0.71	0.74	0.77	0.80	0.83	0.87	0.90	0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.14	1.18	1.21	1.24
36										0.67	0.70	0.73	0.76	0.79	0.82	0.86	0.89	0.92	0.95	0.98	1.01	1.04	1.07	1.10	1.13	1.16	1.19	1.23
37										0.67	0.70	0.72	0.75	0.78	0.81	0.85	0.88	0.91	0.94	0.97	1.00	1.03	1.06	1.09	1.12	1.15	1.18	1.22
38										0.66	0.69	0.72	0.74	0.77	0.81	0.84	0.87	0.90	0.93	0.96	0.99	1.01	1.04	1.07	1.10	1.14	1.17	1.20
39										0.65	0.68	0.71	0.74	0.76	0.80	0.83	0.86	0.89	0.92	0.95	0.97	1.00	1.03	1.06	1.09	1.12	1.15	1.19
40										0.64	0.67	0.70	0.73	0.75	0.79	0.82	0.85	0.88	0.91	0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.14	1.17
41										0.63	0.66	0.69	0.72	0.74	0.78	0.81	0.83	0.87	0.89	0.92	0.95	0.98	1.01	1.04	1.07	1.10	1.13	1.16
42										0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.82	0.86	0.88	0.91	0.94	0.96	0.99	1.02	1.05	1.08	1.11	1.14
43										0.62	0.64	0.67	0.70	0.73	0.75	0.78	0.81	0.84	0.87	0.90	0.92	0.95	0.98	1.01	1.04	1.07		
44										0.61	0.64	0.66	0.69	0.72	0.75	0.77	0.80	0.83	0.86	0.89	0.91	0.94	0.97					
45										0.60	0.62	0.65	0.68	0.71	0.73	0.76	0.79	0.82	0.84	0.87	0.90							

**CP - Corrective factors for Compressor Absorbed Power - EET/EEF Chillers - 20% Propylene Glycol**

CP	Leaving Water Temperature (LWT) [°C]																											
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	
20										0.73	0.73	0.74	0.75	0.75	0.76	0.76	0.78	0.80	0.80	0.80	0.80	0.80	0.82	0.82	0.82	0.83	0.84	
21										0.73	0.73	0.74	0.75	0.75	0.76	0.76	0.78	0.80	0.80	0.80	0.80	0.82	0.82	0.82	0.83	0.84		
22										0.73	0.73	0.74	0.75	0.75	0.76	0.76	0.78	0.80	0.80	0.80	0.80	0.82	0.82	0.82	0.83	0.84		
23										0.73	0.73	0.74	0.75	0.75	0.76	0.76	0.78	0.80	0.80	0.80	0.80	0.82	0.82	0.82	0.83	0.84		
24										0.73	0.73	0.74	0.75	0.75	0.76	0.76	0.78	0.80	0.80	0.80	0.80	0.82	0.82	0.84	0.85	0.86		
25										0.73	0.73	0.74	0.75	0.75	0.76	0.76	0.78	0.80	0.80	0.80	0.80	0.82	0.84	0.85	0.86	0.87	0.88	
26										0.73	0.73	0.74	0.75	0.75	0.76	0.76	0.78	0.80	0.80	0.81	0.82	0.83	0.84	0.86	0.87	0.88	0.89	0.91
27										0.73	0.73	0.74	0.75	0.75	0.77	0.78	0.79	0.81	0.82	0.83	0.84	0.85	0.86	0.88	0.89	0.90	0.91	0.93
28										0.73	0.73	0.75	0.77	0.78	0.79	0.80	0.81	0.83	0.84	0.85	0.86	0.87	0.88	0.90	0.91	0.92	0.94	0.95
29										0.72	0.75	0.77	0.78	0.79	0.81	0.82	0.83	0.85	0.86	0.87	0.88	0.89	0.90	0.92	0.93	0.95	0.96	0.97
30										0.72	0.75	0.78	0.80	0.81	0.83	0.84	0.85	0.87	0.88	0.89	0.90	0.91	0.92	0.94	0.95	0.97	0.98	0.99
31										0.71	0.74	0.77	0.80	0.83	0.85	0.86	0.87	0.89	0.90	0.91	0.92	0.93	0.95	0.96	0.97	0.99	1.00	1.02
32										0.70	0.73	0.76	0.80	0.83	0.86	0.88	0.91	0.92	0.93	0.94	0.96	0.97	0.98	1.00	1.01	1.03	1.04	
33										0.70	0.73	0.76	0.79	0.82	0.85	0.88	0.91	0.93	0.94	0.95	0.96	0.98	0.99	1.00	1.02	1.03	1.05	1.06
34										0.69	0.72	0.75	0.78	0.81	0.84	0.88	0.91	0.95	0.96	0.97	0.99	1.00	1.01	1.03	1.04	1.05	1.07	1.09
35										0.68	0.71	0.74	0.77	0.80	0.84	0.87	0.90	0.97	0.98	1.00	1.01	1.02	1.04	1.05	1.06	1.08	1.10	1.11
36										0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.89	1.00	1.01	1.02	1.03	1.05	1.06	1.07	1.09	1.10	1.12	1.14
37										0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.89</td											

**CD - Corrective factors for Duty - EET/EEF Chillers - 30% Propylene Glycol**

CD	Leaving Water Temperature (LWT) [°C]																									
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
20					0.63	0.65	0.68	0.71	0.74	0.78	0.81	0.84	0.88	0.92	0.95	0.99	1.02	1.06	1.09	1.12	1.16	1.20	1.23	1.27	1.31	1.34
21					0.63	0.65	0.68	0.71	0.74	0.78	0.81	0.84	0.88	0.92	0.95	0.99	1.02	1.06	1.09	1.12	1.16	1.20	1.23	1.27	1.31	1.34
22					0.63	0.65	0.68	0.71	0.74	0.78	0.81	0.84	0.88	0.92	0.95	0.99	1.02	1.06	1.09	1.12	1.16	1.20	1.23	1.27	1.31	1.34
23					0.63	0.65	0.68	0.71	0.74	0.78	0.81	0.84	0.88	0.92	0.95	0.99	1.02	1.06	1.09	1.12	1.16	1.20	1.23	1.27	1.31	1.34
24					0.63	0.65	0.68	0.71	0.74	0.78	0.81	0.84	0.88	0.92	0.95	0.99	1.02	1.06	1.09	1.12	1.16	1.20	1.23	1.27	1.30	1.34
25					0.63	0.65	0.68	0.71	0.74	0.78	0.81	0.84	0.88	0.92	0.95	0.99	1.02	1.06	1.09	1.12	1.16	1.19	1.22	1.26	1.29	1.33
26					0.63	0.65	0.68	0.71	0.74	0.78	0.81	0.84	0.88	0.92	0.95	0.99	1.02	1.05	1.08	1.11	1.15	1.18	1.21	1.25	1.28	1.32
27					0.63	0.65	0.68	0.71	0.74	0.78	0.81	0.84	0.88	0.91	0.95	0.98	1.01	1.04	1.07	1.11	1.14	1.17	1.21	1.24	1.27	1.31
28					0.63	0.65	0.68	0.71	0.74	0.77	0.81	0.84	0.87	0.90	0.94	0.97	1.00	1.04	1.07	1.10	1.13	1.17	1.20	1.23	1.26	1.30
29					0.63	0.65	0.68	0.70	0.74	0.77	0.80	0.83	0.86	0.90	0.93	0.97	1.00	1.03	1.06	1.09	1.12	1.16	1.19	1.22	1.26	1.29
30					0.62	0.65	0.67	0.70	0.73	0.76	0.79	0.83	0.86	0.89	0.92	0.96	0.99	1.02	1.05	1.08	1.11	1.15	1.18	1.21	1.25	1.28
31					0.62	0.64	0.66	0.69	0.72	0.75	0.78	0.82	0.85	0.88	0.91	0.95	0.98	1.01	1.04	1.07	1.10	1.14	1.17	1.20	1.24	1.27
32					0.61	0.63	0.66	0.68	0.71	0.75	0.78	0.81	0.84	0.87	0.91	0.94	0.97	1.00	1.03	1.07	1.10	1.13	1.16	1.19	1.23	1.26
33					0.61	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.87	0.90	0.93	0.96	0.99	1.02	1.06	1.09	1.12	1.15	1.18	1.22	1.25
34					0.60	0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.86	0.89	0.92	0.95	0.98	1.01	1.05	1.07	1.11	1.14	1.17	1.20	1.24
35					0.59	0.61	0.64	0.66	0.69	0.72	0.75	0.79	0.81	0.85	0.88	0.91	0.94	0.97	1.00	1.03	1.06	1.09	1.12	1.16	1.19	1.23
36					0.58	0.61	0.63	0.65	0.68	0.72	0.75	0.78	0.81	0.84	0.87	0.90	0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.15	1.18	1.21
37					0.58	0.60	0.62	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.89	0.92	0.95	0.98	1.01	1.04	1.07	1.10	1.14	1.16	1.20
38					0.57	0.59	0.61	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.88	0.91	0.94	0.97	1.00	1.03	1.06	1.09	1.12	1.15	1.18
39					0.56	0.59	0.61	0.63	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.90	0.93	0.96	0.98	1.02	1.05	1.08	1.11	1.14	1.17
40					0.56	0.58	0.60	0.62	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.89	0.92	0.95	0.97	1.01	1.03	1.06	1.09	1.13	1.16
41					0.55	0.57	0.59	0.62	0.65	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.88	0.91	0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.14
42					0.54	0.56	0.58	0.61	0.64	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.90	0.92	0.95	0.98	1.01	1.04	1.07	1.10	1.13
43					0.54	0.56	0.58	0.60	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.88	0.91	0.94	0.97	1.00	1.02	1.05		
44					0.53	0.55	0.57	0.59	0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.84	0.87	0.90	0.93	0.95					
45					0.52	0.54	0.56	0.58	0.61	0.64	0.67	0.69	0.72	0.75	0.78	0.81	0.83	0.86	0.89							

**CP - Corrective factors for Compressor Absorbed Power - EET/EEF Chillers - 30% Propylene Glycol**

CP	Leaving Water Temperature (LWT) [°C]																									
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
20					0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.75	0.76	0.77	0.78	0.79	0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.83	0.84
21					0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.75	0.76	0.77	0.78	0.79	0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.83	0.84
22					0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.75	0.76	0.77	0.78	0.79	0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.83	0.84
23					0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.75	0.76	0.77	0.78	0.79	0.80	0.80	0.80	0.81	0.81	0.81	0.83	0.84	
24					0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.75	0.76	0.77	0.78	0.79	0.80	0.80	0.80	0.81	0.81	0.83	0.85	0.86	
25					0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.75	0.76	0.77	0.78	0.79	0.80	0.80	0.80	0.82	0.83	0.84	0.85	0.87	0.88
26					0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.75	0.76	0.77	0.78	0.79	0.81	0.82	0.83	0.84	0.85	0.86	0.87	0.89	0.90
27					0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.76	0.78	0.79	0.81	0.82	0.83	0.84	0.85	0.86	0.87	0.88	0.89	0.91	0.92
28					0.71	0.72	0.72	0.73	0.73	0.75	0.76	0.77	0.78	0.79	0.80	0.83	0.83	0.85	0.86	0.86	0.88	0.89	0.90	0.91	0.93	0.94
29					0.71	0.72	0.73	0.74	0.76	0.77	0.78	0.79	0.80	0.81	0.82	0.84	0.86	0.86	0.88	0.89	0.90	0.91	0.92	0.93	0.95	0.96
30					0.73	0.74	0.75	0.76	0.77	0.78	0.80	0.81	0.82	0.83	0.84	0.86	0.88	0.89	0.90	0.92	0.93	0.94	0.96	0.97	0.98	0.99
31					0.75	0.76	0.77	0.78	0.79	0.80	0.81	0.82	0.84	0.85	0.86	0.88	0.89	0.90	0.92	0.93	0.94	0.95	0.97	0.98	1.00	1.01
32					0.77	0.78	0.78	0.80	0.81	0.82	0.83	0.84	0.86	0.87	0.88	0.90	0.91	0.92	0.94	0.95	0.96	0.98	0.99	1.00	1.02	1.03
33					0.79	0.79	0.80	0.81	0.83	0.84	0.85	0.86	0.88	0.89	0.91	0.92	0.94	0.95	0.96	0.97	0.98	1.00	1.01	1.02	1.04	1.06
34					0.80	0.81	0.82	0.83	0.85	0.86	0.87	0.88	0.90	0.91	0.92	0.94	0.96	0.97	0.98	1.00	1.01	1.02	1.03	1.05	1.07	1.08
35					0.82	0.83	0.84	0.85	0.86	0.88	0.89	0.90	0.92	0.93	0.94	0.97	0.98	0.99	1.00	1.02	1.03					

**CD - Corrective factors for Duty - EET/EEF Chillers - 40% Propylene Glycol**

CD	Leaving Water Temperature (LWT) [°C]																									
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
20					0.61	0.64	0.67	0.69	0.72	0.76	0.79	0.82	0.86	0.90	0.93	0.97	1.00	1.04	1.07	1.10	1.15	1.18	1.21	1.26	1.29	1.32
21					0.61	0.64	0.67	0.69	0.72	0.76	0.79	0.82	0.86	0.90	0.93	0.97	1.00	1.04	1.07	1.10	1.15	1.18	1.21	1.26	1.29	1.32
22					0.61	0.64	0.67	0.69	0.72	0.76	0.79	0.82	0.86	0.90	0.93	0.97	1.00	1.04	1.07	1.10	1.15	1.18	1.21	1.26	1.29	1.32
23					0.61	0.64	0.67	0.69	0.72	0.76	0.79	0.82	0.86	0.90	0.93	0.97	1.00	1.04	1.07	1.10	1.15	1.18	1.21	1.26	1.29	1.32
24					0.61	0.64	0.67	0.69	0.72	0.76	0.79	0.82	0.86	0.90	0.93	0.97	1.00	1.04	1.07	1.10	1.15	1.18	1.21	1.26	1.29	1.32
25					0.61	0.64	0.67	0.69	0.72	0.76	0.79	0.82	0.86	0.90	0.93	0.97	1.00	1.04	1.07	1.10	1.14	1.17	1.20	1.24	1.27	1.31
26					0.61	0.64	0.67	0.69	0.72	0.76	0.79	0.82	0.86	0.90	0.93	0.97	1.00	1.03	1.07	1.10	1.13	1.16	1.20	1.23	1.27	1.30
27					0.61	0.64	0.67	0.69	0.72	0.76	0.79	0.82	0.86	0.89	0.93	0.96	1.00	1.03	1.06	1.09	1.12	1.16	1.19	1.22	1.26	1.29
28					0.61	0.64	0.67	0.69	0.72	0.75	0.78	0.82	0.85	0.88	0.92	0.95	0.99	1.02	1.05	1.08	1.11	1.15	1.18	1.21	1.25	1.28
29					0.61	0.64	0.66	0.68	0.71	0.75	0.78	0.81	0.84	0.88	0.91	0.95	0.98	1.01	1.04	1.07	1.10	1.14	1.17	1.20	1.24	1.27
30					0.61	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.87	0.90	0.94	0.97	1.01	1.04	1.07	1.10	1.13	1.16	1.20	1.23	1.26
31					0.60	0.63	0.65	0.67	0.70	0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.96	1.00	1.03	1.06	1.09	1.12	1.15	1.19	1.22	1.25
32					0.60	0.62	0.64	0.66	0.69	0.72	0.75	0.79	0.82	0.85	0.88	0.92	0.95	0.99	1.02	1.05	1.08	1.11	1.14	1.18	1.21	1.24
33					0.59	0.61	0.64	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.88	0.91	0.94	0.98	1.01	1.03	1.07	1.10	1.13	1.16	1.20	1.23
34					0.58	0.61	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.84	0.87	0.90	0.94	0.97	1.00	1.02	1.05	1.09	1.12	1.15	1.18	1.22
35					0.58	0.60	0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.96	0.98	1.02	1.04	1.08	1.11	1.14	1.17	1.20
36					0.57	0.59	0.61	0.64	0.67	0.69	0.72	0.75	0.79	0.82	0.85	0.88	0.92	0.94	0.97	1.01	1.03	1.07	1.10	1.13	1.16	1.19
37					0.57	0.59	0.61	0.63	0.66	0.69	0.71	0.75	0.78	0.81	0.84	0.87	0.91	0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.14	1.18
38					0.56	0.58	0.60	0.62	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.89	0.93	0.95	0.98	1.01	1.04	1.07	1.10	1.14	1.17
39					0.55	0.57	0.59	0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.89	0.91	0.94	0.97	1.00	1.03	1.06	1.09	1.12	1.15
40					0.55	0.57	0.59	0.61	0.63	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.90	0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.14
41					0.54	0.56	0.58	0.60	0.63	0.66	0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.89	0.92	0.95	0.98	1.00	1.03	1.06	1.09	1.12
42					0.53	0.55	0.57	0.59	0.62	0.65	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.88	0.91	0.94	0.96	0.99	1.02	1.05	1.08	1.11
43					0.52	0.54	0.56	0.59	0.61	0.64	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.90	0.92	0.95	0.98	1.01	1.03		
44					0.52	0.54	0.56	0.58	0.60	0.63	0.66	0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.88	0.91	0.94					
45					0.51	0.53	0.55	0.57	0.59	0.62	0.65	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.87							

**CP - Corrective factors for Compressor Absorbed Power - EET/EEF Chillers - 40% Propylene Glycol**

CP	Leaving Water Temperature (LWT) [°C]																										
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
20					0.71	0.72	0.72	0.72	0.73	0.73	0.73	0.74	0.74	0.75	0.76	0.78	0.78	0.79	0.79	0.79	0.80	0.80	0.81	0.81	0.82	0.83	
21					0.71	0.72	0.72	0.72	0.73	0.73	0.73	0.74	0.74	0.75	0.76	0.78	0.78	0.79	0.79	0.80	0.80	0.81	0.81	0.82	0.83		
22					0.71	0.72	0.72	0.72	0.73	0.73	0.73	0.74	0.74	0.75	0.76	0.78	0.78	0.79	0.79	0.80	0.80	0.81	0.81	0.82	0.83		
23					0.71	0.72	0.72	0.72	0.73	0.73	0.73	0.74	0.74	0.75	0.76	0.78	0.78	0.79	0.79	0.80	0.80	0.81	0.81	0.82	0.83		
24					0.71	0.72	0.72	0.72	0.73	0.73	0.73	0.74	0.74	0.75	0.76	0.78	0.78	0.79	0.79	0.80	0.80	0.81	0.83	0.84	0.85		
25					0.71	0.72	0.72	0.72	0.73	0.73	0.73	0.74	0.74	0.75	0.76	0.78	0.78	0.79	0.79	0.81	0.82	0.84	0.85	0.86	0.87		
26					0.71	0.72	0.72	0.72	0.73	0.73	0.73	0.74	0.74	0.75	0.76	0.78	0.78	0.80	0.81	0.82	0.83	0.84	0.85	0.87	0.88	0.89	
27					0.71	0.72	0.72	0.72	0.73	0.73	0.73	0.74	0.76	0.77	0.78	0.80	0.81	0.82	0.83	0.84	0.85	0.86	0.87	0.89	0.90	0.91	
28					0.71	0.72	0.72	0.72	0.73	0.74	0.75	0.76	0.77	0.79	0.80	0.82	0.83	0.84	0.85	0.86	0.87	0.88	0.89	0.91	0.92	0.93	
29					0.71	0.72	0.73	0.74	0.75	0.76	0.77	0.78	0.79	0.80	0.81	0.84	0.85	0.86	0.87	0.88	0.89	0.90	0.91	0.93	0.94	0.96	
30					0.73	0.74	0.75	0.75	0.76	0.77	0.79	0.80	0.81	0.82	0.84	0.85	0.88	0.89	0.90	0.91	0.92	0.94	0.95	0.96	0.97	0.98	
31					0.75	0.75	0.76	0.77	0.78	0.79	0.81	0.82	0.83	0.84	0.85	0.88	0.89	0.90	0.91	0.92	0.93	0.95	0.96	0.97	0.98	1.00	
32					0.76	0.77	0.78	0.79	0.80	0.81	0.82	0.83	0.85	0.86	0.87	0.89	0.90	0.91	0.92	0.93	0.94	0.96	0.97	0.98	0.99	1.01	1.02
33					0.78	0.79	0.80	0.81	0.82	0.83	0.84	0.85	0.87	0.88	0.89	0.92	0.93	0.94	0.95	0.96	0.98	0.99	1.00	1.02	1.03	1.05	
34					0.80	0.81	0.82	0.83	0.84	0.85	0.86	0.88	0.89	0.90	0.91	0.94	0.95	0.96	0.97	0.99	1.00	1.01	1.02	1.04	1.05	1.07	
35					0.82	0.83	0.83	0.84	0.86	0.87	0.88	0.90	0.91	0.92	0.94	0.96	0.97	0.99	1.00	1.01	1.02	1.04	1.05	1.06	1.08		

**CD - Corrective factors for Duty - EET/EEF Chillers - 50% Propylene Glycol**

CD	Leaving Water Temperature (LWT) [°C]																										
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
20						0.60	0.62	0.64	0.67	0.70	0.73	0.77	0.80	0.83	0.87	0.91	0.94	0.98	1.02	1.05	1.09	1.12	1.16	1.19	1.23	1.27	1.31
21						0.60	0.62	0.64	0.67	0.70	0.73	0.77	0.80	0.83	0.87	0.91	0.94	0.98	1.02	1.05	1.09	1.12	1.16	1.19	1.23	1.27	1.31
22						0.60	0.62	0.64	0.67	0.70	0.73	0.77	0.80	0.83	0.87	0.91	0.94	0.98	1.02	1.05	1.09	1.12	1.16	1.19	1.23	1.27	1.31
23						0.60	0.62	0.64	0.67	0.70	0.73	0.77	0.80	0.83	0.87	0.91	0.94	0.98	1.02	1.05	1.09	1.12	1.16	1.19	1.23	1.27	1.31
24						0.60	0.62	0.64	0.67	0.70	0.73	0.77	0.80	0.83	0.87	0.91	0.94	0.98	1.02	1.05	1.09	1.12	1.16	1.19	1.23	1.26	1.30
25						0.60	0.62	0.64	0.67	0.70	0.73	0.77	0.80	0.83	0.87	0.91	0.94	0.98	1.02	1.05	1.09	1.12	1.15	1.18	1.22	1.25	1.29
26						0.60	0.62	0.64	0.67	0.70	0.73	0.77	0.80	0.83	0.87	0.91	0.94	0.98	1.01	1.04	1.08	1.11	1.14	1.18	1.21	1.24	1.28
27						0.60	0.62	0.64	0.67	0.70	0.73	0.77	0.80	0.83	0.87	0.90	0.93	0.97	1.01	1.04	1.07	1.10	1.13	1.17	1.20	1.24	1.27
28						0.60	0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.83	0.86	0.89	0.93	0.96	1.00	1.03	1.06	1.10	1.13	1.16	1.19	1.23	1.26
29						0.60	0.62	0.64	0.67	0.69	0.72	0.75	0.79	0.82	0.85	0.89	0.92	0.95	0.99	1.02	1.05	1.09	1.12	1.15	1.19	1.22	1.25
30						0.59	0.62	0.64	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.88	0.91	0.95	0.98	1.01	1.05	1.08	1.11	1.14	1.18	1.21	1.24
31						0.59	0.61	0.63	0.66	0.68	0.71	0.74	0.77	0.80	0.84	0.87	0.90	0.94	0.97	1.00	1.04	1.07	1.10	1.13	1.17	1.20	1.23
32						0.58	0.60	0.63	0.65	0.67	0.70	0.73	0.76	0.80	0.83	0.86	0.89	0.93	0.96	0.99	1.03	1.06	1.09	1.12	1.15	1.19	1.22
33						0.58	0.60	0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.89	0.92	0.95	0.99	1.02	1.04	1.08	1.11	1.14	1.17	1.21
34						0.57	0.59	0.61	0.64	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.88	0.91	0.94	0.97	1.00	1.03	1.07	1.10	1.13	1.16	1.19
35						0.56	0.58	0.61	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.84	0.87	0.90	0.94	0.97	0.99	1.02	1.06	1.09	1.12	1.15	1.18
36						0.56	0.58	0.60	0.62	0.65	0.68	0.70	0.73	0.77	0.80	0.83	0.86	0.89	0.93	0.95	0.98	1.02	1.04	1.08	1.11		
37						0.55	0.57	0.59	0.61	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.88	0.92	0.94	0.97	1.00	1.03	1.06	1.10	1.13	1.16
38						0.54	0.57	0.59	0.61	0.63	0.66	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.90	0.93	0.96	0.99	1.02	1.05	1.08	1.11	1.15
39						0.54	0.56	0.58	0.60	0.63	0.65	0.68	0.71	0.74	0.77	0.80	0.83	0.86	0.89	0.92	0.95	0.98	1.01	1.04	1.07	1.10	1.13
40						0.53	0.55	0.57	0.59	0.62	0.64	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.88	0.91	0.94	0.97	1.00	1.03	1.06	1.09	1.12
41						0.52	0.54	0.57	0.59	0.61	0.64	0.67	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.90	0.93	0.95	0.99	1.01	1.04	1.08	1.11
42						0.52	0.54	0.56	0.58	0.60	0.63	0.66	0.68	0.71	0.74	0.78	0.80	0.83	0.86	0.89	0.91	0.94	0.97	1.00	1.03	1.07	1.09
43						0.51	0.53	0.55	0.57	0.59	0.62	0.65	0.67	0.70	0.73	0.76	0.79	0.82	0.85	0.88	0.90	0.93	0.96	0.99	1.02		
44						0.50	0.52	0.54	0.56	0.59	0.61	0.64	0.67	0.69	0.72	0.75	0.78	0.81	0.84	0.87	0.89	0.92					
45						0.50	0.51	0.53	0.55	0.58	0.60	0.63	0.66	0.68	0.71	0.74	0.77	0.80	0.82	0.86							

**CP - Corrective factors for Compressor Absorbed Power - EET/EEF Chillers - 50% Propylene Glycol**

CP	Leaving Water Temperature (LWT) [°C]																									
	-10	-9	-8	-7	-6	-5	-4	-3	-2	-1	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
20						0.69	0.70	0.71	0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.78	0.79	0.79	0.79	0.79	0.80	0.80	0.80	0.81	0.82
21						0.69	0.70	0.71	0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.78	0.79	0.79	0.79	0.79	0.80	0.80	0.80	0.81	0.82
22						0.69	0.70	0.71	0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.78	0.79	0.79	0.79	0.79	0.80	0.80	0.80	0.81	0.82
23						0.69	0.70	0.71	0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.78	0.79	0.79	0.79	0.79	0.80	0.80	0.80	0.81	0.82
24						0.69	0.70	0.71	0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.78	0.79	0.79	0.79	0.79	0.80	0.80	0.82	0.83	0.84
25						0.69	0.70	0.71	0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.78	0.79	0.79	0.79	0.81	0.82	0.83	0.84	0.85	0.86
26						0.69	0.70	0.71	0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.78	0.79	0.80	0.81	0.82	0.83	0.84	0.85	0.86	0.88
27						0.69	0.70	0.71	0.71	0.72	0.72	0.73	0.73	0.73	0.74	0.75	0.76	0.77	0.79	0.81	0.82	0.83	0.84	0.85	0.86	0.87
28						0.69	0.70	0.71	0.71	0.72	0.73	0.74	0.75	0.77	0.78	0.79	0.81	0.82	0.83	0.84	0.85	0.86	0.88	0.89	0.90	0.91
29						0.71	0.71	0.72	0.73	0.74	0.75	0.76	0.77	0.78	0.79	0.81	0.83	0.84	0.85	0.86	0.87	0.88	0.90	0.91	0.92	0.93
30						0.72	0.73	0.74	0.75	0.76	0.77	0.78	0.79	0.80	0.81	0.83	0.85	0.86	0.87	0.88	0.90	0.90	0.92	0.93	0.94	0.95
31						0.74	0.75	0.76	0.76	0.77	0.79	0.80	0.81	0.82	0.83	0.85	0.87	0.88	0.89	0.90	0.92	0.93	0.94	0.95	0.96	0.98
32						0.76	0.76	0.77	0.78	0.79	0.80	0.82	0.83	0.84	0.85	0.87	0.89	0.90	0.91	0.92	0.94	0.95	0.96	0.97	0.99	1.00
33						0.77	0.78	0.79	0.80	0.81	0.82	0.83	0.85	0.86	0.87	0.89	0.91	0.92	0.93	0.95	0.96	0.97	0.98	0.99	1.01	1.02
34						0.79	0.80	0.81	0.82	0.83	0.84	0.85	0.87	0.88	0.89	0.91	0.93	0.94	0.96	0.97	0.98	0.99	1.00	1.02	1.03	1.05
35						0.81	0.82	0.83	0.84	0.85	0.86	0.87	0.89	0.90	0.91	0.93	0.95	0.97	0.98	0.99	1.00	1.02	1.03	1.		